


4", 6" or 8" DOMESTIC & FIRE LINE COMBINATION
METER PIT- Using Compact Fire Meter



*4", 6" or 8" Fire Line Meter to be purchased by owner with delivery to the job site and installation by owner. Authority personnel will inspect the installation.

NOTES:

1. Mega-lug glands must be used on all fittings and valves.
2. Concrete Thrust Blocks must be used on all underground bends & tee's.