

Post Construction sample results for the Cottages monitoring well
Samples collected October 19, 2022

DL: Detection Limit is the lowest or minimum level that provides 99% confidence level that the analyte is detected. Any reported result values that are less than the RL are considered estimated values.

RL: Reporting Limit is the lowest or minimum level at which the analyte can be detected

SAMPLE DATE	ANALYSIS DATE	ANALYTE	Result	DL	RL	UNITS
10/19/2021 11:00:00	10/21/2021 14:00:08	Hardness, Drinking Water	115	7.53	20.7	mg equiv. CaCO3/L
10/19/2021 11:00:00	10/27/2021 16:20:00	Oil & Grease	ND	1.65	4.80	mg/l
10/19/2021 11:00:00	10/21/2021 13:55:52	Silver	ND	0.00290	0.00400	mg/l
10/19/2021 11:00:00	10/21/2021 13:54:28	Aluminum	ND	0.0756	0.100	mg/l
10/19/2021 11:00:00	10/21/2021 13:54:28	Barium	0.0334	0.00290	0.0200	mg/l
10/19/2021 11:00:00	10/21/2021 13:55:52	Beryllium	ND	0.000400	0.00200	mg/l
10/19/2021 11:00:00	10/21/2021 14:00:08	Calcium	26.1	2.06	5.00	mg/l
10/19/2021 11:00:00	10/21/2021 13:56:12	Cadmium	ND	0.00160	0.00400	mg/l
10/19/2021 11:00:00	10/21/2021 13:56:12	Chromium	ND	0.00199	0.00500	mg/l
10/19/2021 11:00:00	10/21/2021 13:56:12	Copper	ND	0.00386	0.0100	mg/l
10/19/2021 11:00:00	10/21/2021 13:54:28	Iron	ND	0.185	0.200	mg/l
10/19/2021 11:00:00	10/21/2021 13:54:08	Potassium	2.57	0.328	0.400	mg/l
10/19/2021 11:00:00	10/21/2021 13:54:08	Lithium	ND	0.00720	0.0100	mg/l
10/19/2021 11:00:00	10/21/2021 14:00:08	Magnesium	12.0	0.579	2.00	mg/l
10/19/2021 11:00:00	10/21/2021 13:56:12	Manganese	ND	0.0124	0.0200	mg/l
10/19/2021 11:00:00	10/21/2021 13:54:08	Sodium	27.4	0.793	1.00	mg/l
10/19/2021 11:00:00	10/21/2021 13:56:12	Nickel	ND	0.00560	0.0500	mg/l
10/19/2021 11:00:00	10/21/2021 13:56:12	Zinc	ND	0.0101	0.0200	mg/l
10/19/2021 11:00:00	11/02/2021 18:23:42	Boron	ND	14.2	20.0	ug/l
10/19/2021 11:00:00	10/27/2021 00:16:04	Cobalt	ND	0.119	2.00	ug/l
10/19/2021 11:00:00	10/27/2021 00:16:04	Molybdenum	ND	0.200	0.500	ug/l
10/19/2021 11:00:00	10/27/2021 00:16:04	Lead	ND	0.172	0.500	ug/l
10/19/2021 11:00:00	10/27/2021 00:16:04	Antimony	ND	0.348	1.00	ug/l
10/19/2021 11:00:00	10/27/2021 00:16:04	Selenium	ND	1.67	12.5	ug/l

10/19/2021 11:00:00	10/27/2021 00:16:04	Tin	ND	0.314	2.50	ug/l
10/19/2021 11:00:00	10/27/2021 00:16:04	Thorium	ND	0.594	2.50	ug/l
10/19/2021 11:00:00	10/27/2021 00:16:04	Thallium	ND	0.068	0.500	ug/l
10/19/2021 11:00:00	11/11/2021 16:35:27	Vanadium	ND	0.986	2.50	ug/l
10/19/2021 11:00:00	10/21/2021 12:26:00	Mercury	ND	0.000104	0.000200	mg/l
10/19/2021 11:00:00	10/20/2021 16:49:00	Chloride	33.4	0.136	2.00	mg/l
10/19/2021 11:00:00	10/20/2021 16:49:00	Fluoride	ND	0.099	2.00	mg/l
10/19/2021 11:00:00	10/20/2021 16:49:00	Nitrate as N	2.07	0.085	2.00	mg/l
10/19/2021 11:00:00	10/20/2021 16:49:00	Nitrite as N	ND	0.013	0.400	mg/l
10/19/2021 11:00:00	10/20/2021 16:49:00	Sulfate as SO4	11.8	0.079	2.00	mg/l
10/19/2021 11:00:00	10/28/2021 10:25:00	Phosphorus	0.0150	0.00717	0.0100	mg/l
10/19/2021 11:00:00	10/23/2021 02:59:00	1,2-Dibromo-3-chloropropane	ND	0.011	0.020	ug/l
10/19/2021 11:00:00	10/23/2021 02:59:00	1,2-Dibromoethane (EDB)	ND	0.006	0.020	ug/l
10/19/2021 11:00:00	10/23/2021 02:59:00	1-Chloro-2-fluorobenzene	10.9			ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	1,3,5-Trimethylbenzene	ND	0.25	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	1,2,4-Trimethylbenzene	ND	0.35	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	Benzene	ND	0.31	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	Toluene	ND	0.21	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	Ethylbenzene	ND	0.23	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	Isopropylbenzene	ND	0.35	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	Methyl tert-butyl ether	ND	0.35	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	Naphthalene	ND	0.55	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	Acrylonitrile	ND	0.41	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	Bromobenzene	ND	0.27	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	Bromochloromethane	ND	0.31	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	Bromodichloromethane	ND	0.24	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	4-Bromofluorobenzene	52.2			ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	Bromoform	ND	0.38	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	Bromomethane	ND	0.39	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	sec-Butylbenzene	ND	0.33	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	tert-Butylbenzene	ND	0.39	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	n-Butylbenzene	ND	0.33	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	Carbon disulfide	ND	0.27	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	Chlorobenzene	ND	0.26	1.00	ug/l

10/19/2021 11:00:00	10/22/2021 12:57:00	Chloroethane	ND	0.42	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	Chloroform	ND	0.36	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	Chloromethane	ND	0.39	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	4-Chlorotoluene	ND	0.37	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	2-Chlorotoluene	ND	0.35	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	1,2-Dibromo-3-chloropropane	ND	0.36	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	Dibromochloromethane	ND	0.30	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	1,2-Dibromoethane (EDB)	ND	0.49	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	Dibromomethane	ND	0.36	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	trans-1,4-Dichloro-2-butene	ND	0.23	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	1,2-Dichlorobenzene	ND	0.41	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	1,4-Dichlorobenzene	ND	0.25	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	1,3-Dichlorobenzene	ND	0.32	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	Dichlorodifluoromethane	ND	0.37	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	1,2-Dichloroethane	ND	0.40	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	1,1-Dichloroethane	ND	0.27	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	1,2-Dichloroethane-d4	49.8			ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	trans-1,2-Dichloroethene	ND	0.40	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	cis-1,2-Dichloroethene	ND	0.37	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	1,1-Dichloroethene	ND	0.33	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	2,2-Dichloropropane	ND	0.32	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	1,3-Dichloropropane	ND	0.50	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	1,2-Dichloropropane	ND	0.43	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	trans-1,3-Dichloropropene	ND	0.36	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	1,1-Dichloropropene	ND	0.35	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	cis-1,3-Dichloropropene	ND	0.23	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	Fluorobenzene	50.6			ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	Hexachlorobutadiene	ND	0.50	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	p-Isopropyltoluene	ND	0.34	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	Methylene chloride	ND	0.43	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	n-Propylbenzene	ND	0.29	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	Styrene	ND	0.28	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	1,1,2,2-Tetrachloroethane	ND	0.44	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	1,1,1,2-Tetrachloroethane	ND	0.42	1.00	ug/l

10/19/2021 11:00:00	10/22/2021 12:57:00	Tetrachloroethene	ND	0.46	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	1,2,4-Trichlorobenzene	ND	0.42	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	1,2,3-Trichlorobenzene	ND	0.53	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	1,1,1-Trichloroethane	ND	0.29	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	1,1,2-Trichloroethane	ND	0.42	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	Trichloroethene	ND	0.70	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	Trichlorofluoromethane	ND	0.34	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	1,2,3-Trichloropropane	ND	0.34	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	Vinyl chloride	ND	0.40	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	o-Xylene	ND	0.28	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 12:57:00	m,p-Xylene	ND	0.48	1.00	ug/l
10/19/2021 11:00:00	10/20/2021 07:43:00	Apparent Color	6.00		5.00	Color Units
10/19/2021 11:00:00	10/20/2021 16:44:00	Turbidity	1.24		1.00	NTU
10/19/2021 11:00:00	10/27/2021 23:40:16	Total Alkalinity to pH 4.5	281	9.24	20.0	mg CaCO3/L
10/19/2021 11:00:00	10/27/2021 23:40:16	Specific Conductance (EC)	593		5.00	umhos/cm
10/19/2021 11:00:00	10/20/2021 15:40:00	Total Dissolved Solids	336		20.0	mg/l
10/19/2021 11:00:00	10/23/2021 12:29:00	Amenable Cyanide	ND	0.0120	0.0200	mg/l
10/19/2021 11:00:00	10/27/2021 23:40:16	# pH	7.52			pH Units
10/19/2021 11:00:00	10/26/2021 14:07:00	# Dissolved Oxygen	5.56		0.100	mg/l
10/19/2021 11:00:00	10/29/2021 18:21:00	Total Organic Carbon	1.56	0.258	0.500	mg/l
10/19/2021 11:00:00	10/20/2021 09:12:00	+ Methylene Blue Active Substances	ND	0.0140	0.0250	mg/l
10/19/2021 11:00:00	10/19/2021 18:46:00	E. Coli	200.5	1.0	1.0	MPN/100 ml
10/19/2021 11:00:00	10/19/2021 18:46:00	Total Coliforms	200.5	1.0	1.0	MPN/100 ml
10/19/2021 11:00:00	10/23/2021 12:29:00	Cyanide (Amenable)	ND	0.00600	0.0100	mg/l
10/19/2021 11:00:00	10/22/2021 12:56:15	Ethylene glycol	3.10	2.15	5.00	mg/l
10/19/2021 11:00:00	10/22/2021 12:56:15	Propylene glycol	ND	2.24	5.00	mg/l
10/19/2021 11:00:00	10/22/2021 12:56:15	2-Octanone	85.6			mg/l
10/19/2021 00:00:00	10/23/2021 03:32:00	1,2-Dibromo-3-chloropropane	ND	0.011	0.020	ug/l
10/19/2021 00:00:00	10/23/2021 03:32:00	1,2-Dibromoethane (EDB)	ND	0.006	0.020	ug/l
10/19/2021 00:00:00	10/23/2021 03:32:00	1-Chloro-2-fluorobenzene	11.0			ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	1,3,5-Trimethylbenzene	ND	0.25	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	1,2,4-Trimethylbenzene	ND	0.35	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Benzene	ND	0.31	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Toluene	ND	0.21	1.00	ug/l

10/14/2021 06:05:00	10/22/2021 13:26:00	Ethylbenzene	ND	0.23	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Isopropylbenzene	ND	0.35	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Methyl tert-butyl ether	ND	0.35	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Naphthalene	ND	0.55	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Acrylonitrile	ND	0.41	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Bromobenzene	ND	0.27	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Bromochloromethane	ND	0.31	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Bromodichloromethane	ND	0.24	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	4-Bromofluorobenzene	52.3			ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Bromoform	ND	0.38	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Bromomethane	ND	0.39	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	sec-Butylbenzene	ND	0.33	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	tert-Butylbenzene	ND	0.39	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	n-Butylbenzene	ND	0.33	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Carbon disulfide	ND	0.27	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Chlorobenzene	ND	0.26	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Chloroethane	ND	0.42	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Chloroform	ND	0.36	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Chloromethane	ND	0.39	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	4-Chlorotoluene	ND	0.37	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	2-Chlorotoluene	ND	0.35	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	1,2-Dibromo-3-chloropropane	ND	0.36	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Dibromochloromethane	ND	0.30	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	1,2-Dibromoethane (EDB)	ND	0.49	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Dibromomethane	ND	0.36	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	trans-1,4-Dichloro-2-butene	ND	0.23	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	1,2-Dichlorobenzene	ND	0.41	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	1,4-Dichlorobenzene	ND	0.25	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	1,3-Dichlorobenzene	ND	0.32	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Dichlorodifluoromethane	ND	0.37	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	1,2-Dichloroethane	ND	0.40	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	1,1-Dichloroethane	ND	0.27	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	1,2-Dichloroethane-d4	52.2			ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	trans-1,2-Dichloroethene	ND	0.40	1.00	ug/l

10/14/2021 06:05:00	10/22/2021 13:26:00	cis-1,2-Dichloroethene	ND	0.37	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	1,1-Dichloroethene	ND	0.33	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	2,2-Dichloropropane	ND	0.32	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	1,3-Dichloropropane	ND	0.50	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	1,2-Dichloropropane	ND	0.43	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	trans-1,3-Dichloropropene	ND	0.36	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	1,1-Dichloropropene	ND	0.35	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	cis-1,3-Dichloropropene	ND	0.23	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Fluorobenzene	50.9			ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Hexachlorobutadiene	ND	0.50	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	p-Isopropyltoluene	ND	0.34	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Methylene chloride	ND	0.43	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	n-Propylbenzene	ND	0.29	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Styrene	ND	0.28	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	1,1,2,2-Tetrachloroethane	ND	0.44	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	1,1,1,2-Tetrachloroethane	ND	0.42	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Tetrachloroethene	ND	0.46	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	1,2,4-Trichlorobenzene	ND	0.42	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	1,2,3-Trichlorobenzene	ND	0.53	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	1,1,1-Trichloroethane	ND	0.29	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	1,1,2-Trichloroethane	ND	0.42	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Trichloroethene	ND	0.70	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Trichlorofluoromethane	ND	0.34	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	1,2,3-Trichloropropane	ND	0.34	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	Vinyl chloride	ND	0.40	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	o-Xylene	ND	0.28	1.00	ug/l
10/14/2021 06:05:00	10/22/2021 13:26:00	m,p-Xylene	ND	0.48	1.00	ug/l
10/19/2021 11:00:00	10/22/2021 10:21:00	Arsenic	ND	0.5	1	µg/L
10/19/2021 11:00:00	10/27/2021 04:47:00	PCBs	<0.00008		0.00008	mg/l
10/19/2021 11:00:00	10/27/2021 04:47:00	2,4,5,6-Tetrachloro-m-xylene	0.000926			mg/l
10/19/2021 11:00:00	10/27/2021 04:47:00	Alachlor	<0.0010	0.00005	0.0010	mg/l
10/19/2021 11:00:00	10/27/2021 04:47:00	Chlordane (technical)	<0.0010	0.0003	0.0010	mg/l
10/19/2021 11:00:00	10/27/2021 04:47:00	Endrin	<0.0010	0.00005	0.0010	mg/l
10/19/2021 11:00:00	10/27/2021 04:47:00	Heptachlor	<0.0002	0.00003	0.0002	mg/l

10/19/2021 11:00:00	10/27/2021 04:47:00	Heptachlor Epoxide	<0.0001	0.00003	0.0001	mg/l
10/19/2021 11:00:00	10/27/2021 04:47:00	Hexachlorobenzene	<0.0005	0.00006	0.0005	mg/l
10/19/2021 11:00:00	10/27/2021 04:47:00	Hexachlorocyclopentadiene	<0.0020	0.00006	0.0020	mg/l
10/19/2021 11:00:00	10/27/2021 04:47:00	Methoxychlor	<0.0020	0.00006	0.0020	mg/l
10/19/2021 11:00:00	10/27/2021 04:47:00	Toxaphene	<0.0015	0.0007	0.0015	mg/l
10/19/2021 11:00:00	10/27/2021 04:47:00	Lindane	<0.0001	0.00003	0.0001	mg/l
10/19/2021 11:00:00	10/27/2021 04:47:00	2,4,5,6-Tetrachloro-m-xylene	0.000926			mg/l
10/19/2021 11:00:00	10/28/2021 21:09:00	Dalapon	<0.00100	0.00054	0.00100	mg/l
10/19/2021 11:00:00	10/28/2021 21:09:00	2,4-D	<0.00100	0.00067	0.00100	mg/l
10/19/2021 11:00:00	10/28/2021 21:09:00	Pentachlorophenol	<0.00020	0.00006	0.00020	mg/l
10/19/2021 11:00:00	10/28/2021 21:09:00	Silvex	<0.00025	0.00014	0.00025	mg/l
10/19/2021 11:00:00	10/28/2021 21:09:00	Picloram	<0.00200	0.00045	0.00200	mg/l
10/19/2021 11:00:00	10/28/2021 21:09:00	Dinoseb	<0.00100	0.00051	0.00100	mg/l
10/19/2021 11:00:00	10/28/2021 21:09:00	DCAA	0.0246			mg/l
10/19/2021 11:00:00	10/27/2021 18:02:00	Simazine	<0.0020	0.0004	0.0020	mg/l
10/19/2021 11:00:00	10/27/2021 18:02:00	Atrazine	<0.0020	0.0002	0.0020	mg/l
10/19/2021 11:00:00	10/27/2021 18:02:00	Bis(2-ethylhexyl)adipate	<0.0020	0.0005	0.0020	mg/l
10/19/2021 11:00:00	10/27/2021 18:02:00	Bis(2-Ethylhexyl)phthalate	<0.0050	0.0019	0.0050	mg/l
10/19/2021 11:00:00	10/27/2021 18:02:00	Benzo(a)pyrene	<0.0002	0.0002	0.0002	mg/l
10/19/2021 11:00:00	10/27/2021 18:02:00	1,3-Dimethyl-2-nitrobenzene	0.00504			mg/l
10/19/2021 11:00:00	10/27/2021 18:02:00	Pyrene-d10	0.00531			mg/l
10/19/2021 11:00:00	10/27/2021 18:02:00	p-Terphenyl-d14	0.00584			mg/l
10/19/2021 11:00:00	10/27/2021 18:02:00	Triphenylphosphate	0.00449			mg/l
10/19/2021 11:00:00	10/27/2021 18:02:00	Perylene-d12	0.00401			mg/l
10/19/2021 11:00:00	10/27/2021 18:08:43	Carbofuran	<0.010	0.001	0.010	mg/l
10/19/2021 11:00:00	10/27/2021 18:08:43	Oxamyl	<0.010	0.0009	0.010	mg/l
10/19/2021 11:00:00	10/27/2021 18:08:43	4-Bromo-3,5-Dimethylphenyl N-Methylcarbamate	0.0493		0.010	mg/l
10/19/2021 11:00:00	10/25/2021 18:29:59	Glyphosate	<0.025	0.008	0.025	mg/l
10/19/2021 11:00:00	10/22/2021 19:23:00	Endothall	<0.045	0.034	0.045	mg/l
10/19/2021 11:00:00	10/22/2021 19:23:00	DCAA	0.0216			mg/l
10/19/2021 11:00:00	11/01/2021 11:32:22	Diquat	<0.004	0.002	0.004	mg/l